



Certificate of Compliance

Certificate: 2606926

Master Contract: 258007

Project: 2606926

Date Issued: March 13, 2013

Issued to: Primus Wind Power Inc

938 Quail Street
Lakewood, CO 80215
USA

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Vincent Dang

Issued by: Vincent Dang, P.Eng.

PRODUCTS

CLASS 4211 01 - MOTORS AND GENERATORS

CLASS 4211 81 - MOTORS AND GENERATORS - Certified to US Standards

Wind Turbine Generator, Model AIR 30, Permanently Connect, rated 12 V, 24 V and 48 V, 300 Watts (Continuous), 400 Watts (Peak).

Notes:

1. Wind Turbine Generator, Model Air 30 has been evaluated and is suitable for Type 3R application.
2. Wind Turbine Generator, Model Air 30 has been investigated for shock and fire hazard only, the suitability for installation is subject to the final acceptance of the local authority has jurisdiction.
3. Overcurrent protection must be provided for the controllers in accordance with the NEC and CEC.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 100 - Motors and Generators

UL 1004 - Motors and Generators

CAN/CSA-C22.2 No. 107.2-M89 - Battery Charger (Use as a guide)